

IAPMO R&T OCEANA

7-11 Fullard Road, Narre Warren, Victoria 3805, Australia



IAPMO R&T Oceana is a product certification body which inspects and arranges for the independent laboratory testing of samples taken from the manufacturer's stock or from the market or a combination of both, to verify compliance of the requirements of applicable Standards and Specifications. This activity is coupled with periodic surveillance of the manufacturer's factory and any major subcontractor's site/s as well as the assessment of the manufacturer's Quality Assurance System. This certification is subject to the conditions set forth in the characteristics below and is not to be construed as any recommendation, assurance or guarantee by IAPMO R&T Oceana of the product acceptance by Authorities Having Jurisdiction.

CERTIFICATE OF CONFORMITY

IAPMO R&T Oceana hereby grants to:

Aliaxis Nederland BV

Industrieterrein 11, Panningen, NK 5981 Netherlands

the right to use the WaterMark in accordance with the ABCB Manual for the WaterMark Certification Scheme;— Australian Standards; WaterMark Technical Specifications; and the Plumbing Code of Australia; only in respect of the certified product as described in the WaterMark Certificate of Conformity – Schedule of Certified Product (Refer also IAPMO Product Listing Directory). The Certificate is granted subject to the rules governing the WaterMark Certification Scheme and the Terms and Conditions of the Approved User Agreement and IAPMO Oceana's WaterMark Governance Rules.

Evaluated to:

WMTS-483:2017

Odour control filter

Manufacturer:

Refer to Licence Holder

Licence No.: WM-022829

First Certified: 30 July 2018

Certification Date: 30 July 2021

Expiry Date: 29 July 2026


CEO, The IAPMO Group

This WaterMark certification is for the period indicated herein and is void after the date shown above. Any change in material, manufacturing process, marking or design without having first obtained the approval of IAPMO R&T Oceana, or any evidence of non-compliance with applicable Standards, Specifications or of inferior workmanship, may be deemed sufficient cause for revocation of this certification. Reproduction of or reference to this certificate for advertising purposes may be made only by specific written permission of IAPMO R&T Oceana. Any alteration of this certificate could be grounds for revocation of this certification.

"This certificate is issued by a JAS-ANZ accredited Conformity Assessment Body. The ABCB and JAS-ANZ do not in any way warrant, guarantee or represent that the product the subject of this Certificate conforms to the WaterMark Certification Scheme Rules, nor accepts any liability arising out of the use of the product. The ABCB disclaims to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages and costs arising as a result of the use of the product(s) referred to in this Certificate."



WATERMARK CERTIFICATE OF CONFORMITY

SCHEDULE OF CERTIFIED PRODUCT



Certificate Holder

Aliaxis Nederland BV

A.B.N.:

Industrieterrein 11, Panningen, NK 5981 Netherlands

Manufacturer

Refer to Licence Holder

Standard

WMTS-483:2017

Odour control filter

Licence No. WM-022829

Certification Date: 30 July 2021

Expiry Date: 29 July 2026

First Certified: 30 July 2018

Brand Name	Model Name	Model ID	Product Type	Product Description	Nominal Size	Rated Capacity	Material	Additional Product Information
Studor	Maxi-Filtra	8F-STU019-BLK	Vent Valves	Odour control filter compliant with Method 2 of Appedix C	DN 80/100 push fit	2 L/s @ 0.100 kPa 5 L/s @ 0.250 kPa 8 L/s @ 0.500 kPa	ABS	Replacement activated carbon filter to reduce hydrogen sulfide gas and ammonia

END RECORD

END RECORD

CEO, The IAPMO Group