

Directory Search Results

WRAS Approval Number: 2012058

Approved Product

Range of waste water heat recovery systems incorporating a twin wall copper coil (iZi models) or stainless steel (PiPe models). Maximum working pressure 10.0 bar. Cold water use only.

- **Section:** 1350 Heat Exchangers (?section=1350)
- **WRAS Approval Number:** 2012058
- **Expiry date:** 31/12/2025
- **Size:** ½" BSP (M) (iZi 30 & 40) or ¾" BSP (F) (PiPe 65 & 70)
- **Marking:** ZypHO, Model, WRAS and technical info on adhesive label located on plastic casing.
- **Installation Requirements** R001 (/approvals/testing-requirements/installation_requirements/irn_r001)
- **Model**
 - ZYPHO iZi 30,
 - ZYPHO iZi 40,
 - ZYPHO PiPe 65,
 - ZYPHO PiPe 70
- **Manufacturer:** ZypHO, SA View All Listings by this Company (?company=21209)